

DEPARTMENT OF LIBRARY & INFORMATION SCIENCE
UNIVERSITY OF KERALA
Thiruvananthapuram-695034
Re –accredited at the “A” Grade Level by NAAC



Dr. B. MINI DEVI
Head of the Department
dliskerala2@gmail.com

Phone: 0471-2577779

www.keralauniversity.ac.in/dlis

DLIS/ 112/ 2020

Date: 09/01/2020

Quotation Schedule

Supply and Installation of UPS in the Department

UPS				
Sl. No.	Qty	Specifications	Rate	Amount (In Rs)
1.	1	Supply and installation of UPS ONLINE 5 KVA Single phase AC input (180-240V) Single phase AC output(230V) True Sine wave output Output power factor-above 0.8 Generator compatible Status indicators for load levels Audio alarms for battery mode,low battery,overload etc. Backup time for 60 minutes using SMF battery(Quanta,Exide or Compatible 3 years warranty for UPS and battery		

ABSTRACT	
Supply and Installation of UPS	
Grand Total	