

DEPARTMENT OF PSYCHOLOGY

University of Kerala

(Established as University of Travancore by the Travancore University Act in 1937 and reconstituted as University of Kerala by the Kerala University Act of 1957 and presently governed by the Kerala University Act of 1974 passed by the Kerala State Legislative Assembly) (Re-accredited by NAAC with 'A' Grad

Dr. Jasseer J
Prof and Head



Kariavattom, 695581
Trivandrum, India
Phone: office: 91-471 2308304
Mobile: 9447221421
Emaildrjasseer@yahoo.co.in

No. PSY/ 46/2023

16.02.2023

QUOTATION

Dear Madam/sir,


Sealed quotations are invited from reputed firms for the supply of One Air Conditioner as per the specifications given below.

The air conditioner is intended to install in the room of Centre for Geriatric Studies attached to the Department of Psychology, University of Kerala. Interested firms are requested to submit quotations to the Professor and Head, Department of Psychology, University of Kerala, Kariavattom Campus, Thiruvananthapuram-695581 by post or in person. The last date for the submission of quotation will be 28/02/2023.

For more details contact -9447221421

A handwritten signature in black ink, appearing to read 'Dr. Jasseer J'.

Prof and Head



HEAD
DEPARTMENT OF PSYCHOLOGY
UNIVERSITY OF KERALA
KARIAVATTOM CAMPUS

<p>od346050/2020_2021</p> <p>Supply, installation, testing and commissioning the following capacity of wall mounting, high energy efficient, single phase, inverter type, split air conditioner unit (IDU) having 5-star rating as per BEE, fitted with hermetically sealed rotary compressor (ODU) suitable for eco-friendly and energy efficient refrigerants R-32A / R-410A, conforming to IS: 1391 Part-2 1992 (with latest amendments except power consumption norms) suitable for operation on 230 V, 50 Hz AC supply and capable of performing functions such as cooling, dehumidifying, air circulating, filtering etc and having features of long distance piping flexibility, wide angle air flow, IDU noise level < 43 dB (A) and ODU noise level < 56 dB (A) as required. The condensing and evaporating coils should be made of copper tubes (100% copper) and a standard length of upto 3 metres of soft drawn bright annealed copper refrigerant pipes of suitable sizes should be supplied along with the AC unit for the function of suction and discharge and the copper pipes should be properly insulated with 10 mm thick closed cell Class O elastomeric nitrile rubberised foam sleeve insulation. A standard length of upto 3 metres of suitable size ISI marked flexible copper control cable for electrically connecting IDU and ODU of AC unit and microprocessor based wireless remote controller with required number of suitable batteries should also be supplied along with the AC unit as required. There should be 3 numbers of comprehensive free service for the AC unit (IDU & ODU) for one year, applicable from the date of commissioning. One year replacement warranty should be provided for the entire AC unit along with two years exclusive warranty for PCB and ten years exclusive warranty for the compressor. (Make- Panasonic, Voltas, Carrier, Mitsubishi, Blue Star or Daikin).
2-Ton 5-star split type inverter AC unit.</p>	1	each
<p>od346053/2020_2021</p> <p>Supply and providing 25 mm PVC pipe on wall as drain pipe for AC unit with all required accessories including cutting and making good the walls, colour washing etc as required.</p>	3	meter

<p>od346054/2020_2021</p> <p>Supply, installation, testing and commissioning of wall mounting type 5 kVA voltage stabilizer with input voltage range of 170 V - 270 V and having features of high power efficiency, intelligent time delay system, Low & High voltage cut-off protection, built-in thermal overload protection, LED indications etc suitable for single phase 2-Ton air conditioner unit with three years warranty and three months replacement guarantee. (Make: V-Guard, V-Stab, Pioneer, Crompton or Microtek)</p>	1	each
<p>90.10.3.23</p> <p>Supply and Fixing the following modular switches & accessories in the existing front plates and giving necessary connections as required (RoHS compliant)16A 3 pin plug top</p>	1	each
<p>Supply and fixing powder coated ODU mounting stands</p>	1	Pair



[Handwritten Signature]
HEAD
DEPARTMENT OF PSYCHOLOGY
UNIVERSITY OF KERALA
KARIAVATTOM CAMPUS