University of Kerala Department of Physics Kariavattom Campus, Thiruvananthapuram – 695581 KERALA

No.Phy/ 119 /2020-2021

11-12-2020

Quotation Notice

Competitive Quotations are invited from interested vendors inside Kerala for the supply of **one number of 5KVA 96 V UPS with backup** for providing stable 24x7 power supply for Glove box machine in the research lab of Department of Physics, Kariavatom as follows:

Conditions

- 1. Total amount including all charges and taxes should be quoted.
- 2. GST % details should be mentioned (GST No of University: 32AAAJU0328F1ZJ)
- Complaints with the items supplied should be rectified/ replaced to the satisfaction of the University by the suppliers at their own cost.
- 4. Payment will be made only after the supply and installment of the items at our own site.
- 5. The undersigned reserves the right to reject /accept any quotation without assigning any reason.

The sealed quotations should be addressed to the undersigned super scribed as 'Quotations for the supply of **one number of 5KVA 96 V UPS with backup** for use in research lab for Glove Box machine'. Quotes should be inclusive of the cost, freight, taxes, etc. The UPS should be installed in the Department of Physics, University of Kerala. Last date of receipt of quotation is at 02.00 pm on 29.12.2020. The quotations will be opened at 2.00 pm on 30.12.2020 in presence of the vendors then present, following all COVID 19 restrictions imposed by the Government. Detailed specification is attached.

WARRANT ON THE WARRANT OF PHYSICS AND THE WARRAT

/The Head Department of Physics University of Kerala Kariavattom, Thiruvananthapuram

Head-in charge
Department of Physics
University of Korala
Karlavatiom - 695 581

No	Item	Description/Remark
1	5KVA 48	1. Single phase input & Single Phase out
	VDC online	2. Built in Galvanic Isolation Transformer
	UPS	3. Pure sine wave
		4. Bypass, overload protection and LCD Display
		5. Tubular battery 8 Numbers with 2 hour backup
		6. Warranty not less than three years for UPS.
		7. Warranty not less than 5 years for Battery.
		8. Include a compliance statement.



Head-in charge Department of Physics University of Kerala Kariavattom - 695 B