

കാട്ടേഷൻ / ലേല പരസ്യം

കേരള സർവകലാശാല കാര്യവട്ടം ക്യാമ്പസിലെ ഫിലോസഫി പഠന വകുപ്പിലെ ലൈബ്രറിയിൽ AC വാങ്ങുന്നതിന് No.17632/Ad BIV A/2023/UOK dated:08.01.2024 കത്ത് പ്രകാരം മുദ്ര വച്ച കാട്ടേഷനുകൾ ക്ഷണിച്ചു കൊള്ളുന്നു. കാട്ടേഷനുകൾ "ഫിലോസഫി പഠന വകുപ്പിൽ AC വാങ്ങുന്നതിനു വേണ്ടിയുള്ള കാട്ടേഷൻ " എന്ന് രേഖപ്പെടുത്തി സീൽ ചെയ്ത കവറിൽ 20.01.2024 വൈകുന്നേരം 3.00 മണിക്ക് മുൻപായി ഹെഡ് ഓഫ് ദി ഡിപ്പാർട്ട്മെന്റ് ,ഡിപ്പാർട്ട്മെന്റ് ഓഫ് ഫിലോസഫി ,യൂണിവേഴ്സിറ്റി ഓഫ് കേരള ,കാര്യവട്ടം ക്യാമ്പസ് -695581 എന്ന വിലാസത്തിൽ അയക്കേണ്ടതാണ്.കാട്ടേഷൻ നിരസിക്കാനുള്ള അധികാരം ഡിപ്പാർട്ട്മെന്റ് തലവനിൽ നിക്ഷിപ്തമാണ്. ചുവടെ ചേർത്തിരിക്കുന്ന വിശദശാഠങ്ങൾ നിർബന്ധമായും കാട്ടേഷനിൽ ഉൾപ്പെടുത്തേണ്ടതാണ്.

വിശദാഠങ്ങൾ ചുവടെ ചേർക്കുന്നു.

Supply, installation, testing and commissioning the following capacity of wall mounting, high energy efficient, single phase, inverter type, split air conditioner unit 1.5TR (1TR-12000BTU/Hr +/- 10%) (IDU) having 5-star rating as per BEE, ISEER latest with minimum 5.0 fitted with hermetically sealed rotary compressor (ODU) suitable for eco-friendly and energy efficient refrigerants R-32A / R-290, conforming to IS: 1391 Part-2 1992 (with latest amendments except power consumption norms) suitable for operation on 230 V, 50 Hz AC supply and capable of performing functions such as cooling, dehumidifying, air circulating, filtering etc and having features of long distance piping flexibility, wide angle air flow, IDU noise level < 43 dB (A) and ODU noise level < 56 dB (A) as required. The condensing and evaporating coils should be made of copper tubes (100% copper) and a standard length of upto 3 metres of soft drawn bright annealed copper refrigerant pipes of suitable sizes should be supplied along with the AC unit for the function of suction and discharge and the copper pipes should be properly insulated with 10 mm thick closed cell Class O elastomeric nitrile rubberised foam sleeve insulation. A standard length of upto 3 metres of suitable size ISI marked flexible copper control cable for electrically connecting IDU and ODU of AC unit and microprocessor based wireless remote controller with required number of suitable batteries should also be supplied along with the AC unit as required. There should be 3 numbers of comprehensive free service for the AC unit (IDU & ODU) for one year, applicable from the date of commissioning.

Two-year warranty should be provided for the entire AC unit, along with two years exclusive warranty for PCB and repair guarantee for next three years.

Ten years exclusive warranty for the compressor. (Make- Panasonic, Voltas, Carrier, Mitsubishi, Blue Star or Daikin). <2-Ton 5-star split type inverter AC unit.

Kariavattom  
09.01.2024



*[Handwritten Signature]*  
Head

Department of Philosophy